



MOT--170  
DAYTON 6Z820  
110/230 VAC  
60 RPM

2.3 FLA  
1/6 HP

NOTE:  
INSULATE RED WIRE FOR 120 VAC OPERATION

OVERLOAD RELAY (OLR)  
SETTING: 2.5 A

CUSTOMER: \_\_\_\_\_  
EQUIP #: \_\_\_\_\_ SHEET 1 OF 1

REVISIONS
1 08/19/09 SLM TLBLK-DAYTON NOT BALDOR
2 07/12/16 CB PREFIX FOR BREAKER DEVICE ID WAS "CB"

THIS DOCUMENT IS BEING TRANSMITTED:	
X	FOR REVIEW AND APPROVAL WORK WILL PROCEED UPON RECEIPT OF APPROVED DOCUMENTS
	CERTIFIED FOR PRODUCTION ONLY FOR INFORMATION ONLY
	CERTIFIED "AS-BUILT" FOR INFORMATION ONLY
SIGNATURE _____	DATE _____

NOTE: THIS DOCUMENT IS CONFIDENTIAL, AND CONTAINS INFORMATION WHICH IS PROPRIETARY TO SEC. IT IS PROVIDED IN CONFIDENCE AND UPON THE CONDITION THAT NEITHER IT NOR THE INFORMATION CONTAINED IN IT WILL BE COPIED, DISCLOSED, OR USED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF SEC.		
DO NOT SCALE DWG. ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED TOLERANCES FOR ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED		
	MACH. PARTS	STRUCT.
1/X	± 1/8	± 1/2
.X	± 0.1	± 0.3
.XX	± 0.01	± 0.06
.XXX	± 0.005	± 0.030
ANG.	± 1/2"	± 1"
REMOVE ALL BURRS AND SHARP EDGES UNLESS OTHERWISE NOTED	FILENAME 03936B01	DATE 12/10/08
THIRD ANGLE PROJECTION	DRAWN SLM	DATE CHECKED
	DWG. NO. 10-03936B	DATE APPROVED



B1 1/6 HP 120 VAC DAYTON MOTOR  
ELECTRICAL WIRING DIAGRAM  
SENTRY P/N 83010600

REVISION 2