



MOT-166
 1/3 HP
 6.2/2.9-3.1 FLA
 115/230 VAC
 60 RPM
 60 HZ

MS-151
 OVERLOAD RELAY (OLR)
 SETTING: 2.9 A

REVISIONS
 1 07/12/16 CB
 PREFIX FOR BREAKER
 DEVICE ID WAS "CB"

THIS DOCUMENT IS BEING TRANSMITTED:
 FOR REVIEW AND APPROVAL WORK WILL PROCEED UPON RECEIPT OF APPROVED DOCUMENTS
 CERTIFIED FOR PRODUCTION ONLY FOR INFORMATION ONLY
 CERTIFIED 'AS-BUILT' FOR INFORMATION ONLY
 SIGNATURE _____ DATE _____

NOTE:
 THIS DOCUMENT IS CONFIDENTIAL, AND CONTAINS INFORMATION WHICH IS PROPRIETARY TO SEC. IT IS PROVIDED IN CONFIDENCE AND UPON THE CONDITION THAT NEITHER IT NOR THE INFORMATION CONTAINED IN IT WILL BE COPIED, DISCLOSED, OR USED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF SEC.
 REMOVE ALL BURRS AND SHARP EDGES UNLESS OTHERWISE NOTED

DO NOT SCALE DWG.
 ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED
 TOLERANCES FOR ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED

	MACH. PARTS	STRUCT.
1/X	± 1/8	± 1/2
.X	± 0.1	± 0.3
.XX	± 0.01	± 0.06
.XXX	± 0.005	± 0.030
ANG.	± 1/2°	± 1°

SA/E 1/3 HP 120 VAC
 LEESON 102930 MOTOR
 ELECTRICAL WIRING DIAGRAM
 SENTRY P/N 20291000

FILENAME: 03936J01
 DATE DRAWN: 12/10/08
 DATE CHECKED: _____
 DATE APPROVED: _____
 DWG. NO.: 10-03936J
 REVISION: 1

CUSTOMER: _____
 EQUIP #: _____ SHEET 1 OF 1