



	L1	L2	JOIN
HIGH STD	P1	T4, T5	T2,T3,T8
HIGH OPP	P1	T4, T8	T2,T3,T5
LOW STD	P1	T2,T4,T5	P2,T3,T8
LOW OPP	P1	T2,T4,T8	P2,T3,T5

1. STD ROTATION IS CCW FACING
END OPPOSITE SHAFT
EXTENSION.

1111 from 112 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222

CUSTOMER: _____ SHEET 1 OF 1
EQUIP #: _____

REVISIONS	DATE	BY
0	11/1/12	CB
1	2/19/13	CB
2	07/12/16	CB

INITIAL RELEASE
CORRECTED MTR JUMPER (WAS 3-5, NOW 3-6)
PREFIX FOR BREAKER DEVICE ID WAS "CB"

THIS DOCUMENT IS BEING TRANSMITTED:	
X	FOR REVIEW AND APPROVAL WORK WILL PROCEED UPON RECEIPT OF APPROVED DOCUMENTS
	CERTIFIED FOR PRODUCTION ONLY FOR INFORMATION ONLY
	CERTIFIED "AS-BUILT" FOR INFORMATION ONLY
SIGNATURE _____	DATE _____

NOTE:		
THIS DOCUMENT IS CONFIDENTIAL, AND CONTAINS INFORMATION WHICH IS PROPRIETARY TO SEC. IT IS PROVIDED IN CONFIDENCE AND UPON THE CONDITION THAT NEITHER IT NOR THE INFORMATION CONTAINED IN IT WILL BE COPIED, DISCLOSED, OR USED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF SEC.		
REMOVE ALL BURRS AND SHARP EDGES UNLESS OTHERWISE NOTED	DO NOT SCALE DWG. ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED. TOLERANCES FOR ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED:	
	MACH. PARTS	STRUCT.
	1/X ± 1/8	± 1/2
	.X ± 0.1	± 0.3
	.XX ± 0.01	± 0.06
	.XXX ± 0.005	± 0.030
	ANG. ± 1/2°	± 1°
FILENAME 03936R01	DATE DRAWN 11/1/12	DATE CHECKED
	DWG. NO. 10-03936R	DATE APPROVED
THIRD ANGLE PROJECTION		REVISION 2

SENTRY www.sentry-equip.com

B1 XP-RATED 1/4HP 120VAC
MARATHON MODEL 56C17E5319
ELECTRICAL WIRING DIAGRAM
SENTRY P/N 4-05220J